



Certificate / Certificat Zertifikat / 合格証

NAF 070721 C002

exida hereby confirms that the:

NAF - Setball Ball Sector Valves

DN 25 – DN 700 (1" – 28")

PN 10 – PN 40 (ANSI Class 150 & 300)

Flowserve - NAF AB

SE-581 87 Linköping, Sweden

Have been assessed per the relevant requirements of:

IEC 61508 : 2010 Parts 1-7

and meets requirements providing a level of integrity to:

Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type A, Route 2_H Device

**PFH/PFD_{avg} and Architecture Constraints
must be verified for each application**

Safety Function:

The Ball Valve will move to the designed safe position per the actuator design within the specified safety time.

Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.

The manufacturer
may use the mark:



Revision 3.1 March 31, 2021
Surveillance Audit Due
April 1, 2024



Evaluating Assessor

Certifying Assessor

NAF 070721 C002

Systematic Capability: SC 3 (SIL 3 Capable)**Random Capability: Type A, Route 2_H Device****PFH/PFD_{avg} and Architecture Constraints
must be verified for each application****Setball Series
Ball Sector Valves****Systematic Capability:**

The products have met manufacturer design process requirements of Safety Integrity Level (SIL) 3. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.

Random Capability:

The SIL limit imposed by the Architectural Constraints must be met for each element. This device meets *exida* criteria for Route 2_H.

IEC 61508 Failure Rates in FIT*, Clean Service

Application	λ_{SD}	λ_{SU}	λ_{DD}	λ_{DU}
Full Stroke	0	0	0	510
Tight Shut-Off	0	0	0	1473
Open on Trip	0	165	0	345

* FIT = 1 failure / 10⁹ hours

SIL Verification:

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFH/PFD_{avg} considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each element must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification:

Assessment Report: NAF 07/07-21 R005 V5 R1 (or later)

Safety Manual: NFENDS4151



80 N Main St
Sellersville, PA 18960