



Certificate of Conformity

Germanischer Lloyd

03237 HH O

Certificate No.

Butterfly Valve Type HGF DN 50

Subject: Fire Safe Test acc. to BS 6755: part 2: 1987

Supplier: GEFA Dortmund/Germany

Manufacturer: GEFA Dortmund/Germany

It is to confirm that a butterfly valve type HGF, DN 50, PN 25, with hand lever has been tested for fire safety in accordance with BS 6755: part 2: 1987 as per test report dated 27th June 2003.

The valve tested complied with all requirements as per BS 6755. part 2: 1987.

Hamburg, 17th July 2003

Germanischer Lloyd

Offshore and Industrial Services

E. A. Hinrichsen
for Eckhard Hinrichsen
Head of Department



INDUSTRIAL SERVICES
20007

id
Frank Heise
Project Manager

The latest edition of the "General Terms and Conditions for Classification" and the "General Terms and Conditions" respectively are applicable. German law applies.
Es gelten die "Allgemeinen (Geschäfts-)Bedingungen für die Klassifikation" bzw. die "Allgemeinen Geschäftsbedingungen" in ihrer jeweils neuesten Fassung. Es gilt deutsches Recht.