



IECEx Certificate of Conformity

INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification Scheme for Explosive Atmospheres

for rules and details of the IECEx Scheme visit www.iecex.com

Certificate No.: IECEx TUR 14.0018X issue No.:1
Status: **Current**
Date of Issue: **2015-03-17** Page 1 of 4

Certificate history:
Issue No. 1 (2015-3-17)
Issue No. 0 (2014-6-3)

Applicant: **KROHNE Pressure Solutions GmbH**
Oberbecksenerstraße 76
32547 Bad Oeynhausen
Germany

Electrical Apparatus: **Pressure Transmitter**
Optional accessory: OPTIBAR PC 5060 C and OPTIBAR PM 5060 C

Type of Protection: **Ex i Ex d**

Marking: **Ex d ia IIC T6...T1 Ga/Gb, Gb**

Approved for issue on behalf of the IECEx
Certification Body:


Dipl.-Ing. Klauspeter Graffi

Position:

Head of Certification Body

Signature:
(for printed version)

Date:


2015-04-27

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting the [Official IECEx Website](http://www.iecex.com).

Certificate issued by:

TUV Rheinland Industrie Service GmbH
Am Grauen Stein
51105 Cologne
Germany





IECEx Certificate of Conformity

Certificate No.: IECEx TUR 14.0018X

Date of Issue: 2015-03-17

Issue No.: 1

Page 2 of 4

Manufacturer: **KROHNE Pressure Solutions GmbH**
Oberbecksenerstraße 76
32547 Bad Oeynhausen
Germany

Additional Manufacturing location
(s):

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended.

STANDARDS:

The electrical apparatus and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards:

IEC 60079-0 : 2011 Edition: 6.0	Explosive atmospheres - Part 0: General requirements
IEC 60079-1 : 2007-04 Edition: 6	Explosive atmospheres - Part 1: Equipment protection by flameproof enclosures "d"
IEC 60079-11 : 2011 Edition: 6.0	Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "i"
IEC 60079-26 : 2006 Edition: 2	Explosive atmospheres - Part 26: Equipment with equipment protection level (EPL) Ga

This Certificate does not indicate compliance with electrical safety and performance requirements other than those expressly included in the Standards listed above.

TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in

Test Report:

DE/TUR/ExTR14.0018/00

DE/TUR/ExTR14.0018/01

Quality Assessment Report:

DE/BVS/QAR13.0005/00



IECEx Certificate of Conformity

Certificate No.: IECEx TUR 14.0018X

Date of Issue: 2015-03-17

Issue No.: 1

Page 3 of 4

Schedule

EQUIPMENT:

Equipment and systems covered by this certificate are as follows:

Pressure Transmitter

OPTIBAR PC 5060 C (*).WE/WZ/W6/W7/VE*****(*)Z/H/A/S/T/P/F*****

OPTIBAR PM 5060 C (*).WE/WZ/W6/W7/VE*****(*)Z/H/A/S/T/P/F*****

$U_i = 9,6 \dots 35\text{VDC}$, $U_m = 253\text{VAC}$

CONDITIONS OF CERTIFICATION: YES as shown below:

1. At the plastic parts of the Pressure Transmitter there is a danger of ignition by electrostatic discharge. Observe safety instructions of manufacturer and warning label.
2. For EPL Ga/Gb applications, at the metallic parts of the Pressure Transmitter made of light metal there is a danger of ignition by impact or friction. Observe manual of the manufacturer.
3. For EPL Ga/Gb applications and at risks by pendulum or vibration the respective parts of the Pressure Transmitter have to be secured effectively against these dangers. Observe manual of the manufacturer.
4. For EPL Ga/Gb applications the medium tangent materials of the Pressure Transmitter have to be resistant to the media. Observe manual of the manufacturer.
5. For the type with separate housing of the pressure transmitter, the potential equalization has to exist in the complete course of the erection of the connecting cable between the electronics housing and the measuring sensor housing.



IECEx Certificate of Conformity

Certificate No.: IECEx TUR 14.0018X

Date of Issue: 2015-03-17

Issue No.: 1

Page 4 of 4

DETAILS OF CERTIFICATE CHANGES (for issues 1 and above):

For complete Type designation refer to manufacturers documents. In the future, the pressure transmitter type OPTIBAR may be manufactured in the version with electronics for Profibus PA and Foundation Fieldbus, available in an 1 chamber or a 2 chamber housing.



Attachment to Certificate
IECEX TUR 14.0018 X
Revision 1

Attachment to to Certificate IECEX TUR 14.0018/01 X

Device: Pressure Transmitter
OPTIBAR PC 5060 C (*).WE/WZ/W6/W7/VE*****(*)Z/H/A/S/T/P/F*****
OPTIBAR PM 5060 C (*).WE/WZ/W6/W7/VE*****(*)Z/H/A/S/T/P/F*****

Manufacturer: KROHNE Pressure Solutions GmbH

Address: Oberbecksenerstraße 76
32547 Bad Oeynhausen
Germany

General product information:

For complete Type designation refer to manufacturers documents.

In the future, the pressure transmitter type OPTIBAR may be manufactured in the version with electronics for Profibus PA and Foundation Fieldbus, available in an 1 chamber or a 2 chamber housing.

OPTIBAR * 5060 VGK5/6/D*A/W/V E/Z/6/7 with electronics Z (4...20 mA), H (4...20 mA/HART®) or A (4...20 mA/HART® with SIL qualification), version with single chamber housing A, V	
Supply and signal circuit: (Terminals 1[+], 2[-] in electronic compartment)	• $U_i = 9.6...35$ VDC • $U_m = 253$ VAC
Indicating and adjustment circuits: (terminals 5, 6, 7, 8)	For connection of an OPTIBAR * 5060 in protection type flameproof enclosure "Ex d ia" with integrated electronics S or T as electronic differential pressure measurement.
Circuit for the display and adjustment module: (spring contacts in the electronic compartment)	For connection to the display and adjustment module.

OPTIBAR * 5060 VGK5/6/D*A/W/V E/Z/6/7 with electronics Z (4...20 mA), H (4...20 mA/HART®), A (4...20 mA/HART® with SIL qualification), version with double chamber housing D, W	
Supply and signal circuit: (Terminals 1[+], 2[-] in terminal compartment)	• $U_i = 9.6...35$ VDC • $U_m = 253$ VAC
Indicating and adjustment circuits: (terminals 5, 6, 7, 8)	For connection of an OPTIBAR * 5060 in protection type flameproof enclosure "Ex d ia" with integrated electronics S or T as electronic differential pressure measurement.
Circuit for the display and adjustment module: (spring contacts in the electronic compartment)	For connection to the display and adjustment module.



Attachment to Certificate
IECEX TUR 14.0018 X
Revision 1

OPTIBAR * 5060 VGK5/6/D*A/W/V E/Z/6/7 with electronics P (Profibus PA), F (Foundation Fieldbus), version with single chamber housing A, V	
Supply and signal circuit: (Terminals 1[+], 2[-] in electronic compartment)	<ul style="list-style-type: none"> • $U_i = 9.6...35$ VDC • $U_m = 253$ VAC
Indicating and adjustment circuits: (terminals 5, 6, 7, 8)	For connection of an OPTIBAR * 5060 in protection type flameproof enclosure "Ex d ia" with integrated electronics S or T as electronic differential pressure measurement.
Circuit for the display and adjustment module: (spring contacts in the electronic compartment)	For connection to the display and adjustment module.

OPTIBAR * 5060 VGK5/6/D*A/W/V E/Z/6/7 with electronics P (Profibus PA), F (Foundation Fieldbus), version with double chamber housing D, W	
Supply and signal circuit: (Terminals 1[+], 2[-] in terminal compartment)	<ul style="list-style-type: none"> • $U_i = 9.6...35$ VDC • $U_m = 253$ VAC
Indicating and adjustment circuits: (terminals 5, 6, 7, 8)	For connection of an OPTIBAR * 5060 in protection type flameproof enclosure "Ex d ia" with integrated electronics S or T as electronic differential pressure measurement.
Circuit for the display and adjustment module: (spring contacts in the electronic compartment)	For connection to the display and adjustment module.

OPTIBAR * 5060 VGK5/6/D*A/W/V E/Z/6/7 with electronics S or T	
Supply and signal circuit: (Terminals 5,6,7,8 in electronics compartment)	For connection to an OPTIBAR * 5060 VGK5/6/D*A/W/V E with integrated electronics H (4...20 mA/HART®), A (4...20 mA/HART® with SIL qualification), P (Profibus PA), F (Foundation Fieldbus) for electronic differential pressure measurement

OPTIBAR * 5060 VGK5/6/D*A/W/V E/Z/6/7 version with separate cable outlet (all electronics)	
Circuit between sensor and external electronics (terminal 1 - yellow, terminal 2 - white, terminal 3 - red, terminal 4 - black)	<p>in protection type intrinsic safety Ex ia IIC</p> <p>For the OPTIBAR * 5060 VGK5/6/D*A/W/V E in the version with the permanently mounted cable to the measuring sensor unit and external electronics, the length of the supplied cable between the external housing and the measuring sensor unit should not exceed 180 m.</p>