



Certificate / Certificat Zertifikat / 合格証

OHL 1407085 P0037 C001.1

exida hereby confirms that the :

Ball Valve series BBF

**Böhmer GmbH
Sprockhövel, Germany**

The manufacturer
may use the mark:



Has been assessed per the relevant requirements of:

IEC 61508:2010 Parts 1 – 7

and meets requirements providing a level of integrity to:

Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type A, Route 2_H Device

**PFD_{AVG} and Architecture Constraints
must be verified for each application**

Valid until December 1, 2018.
Rev 1.1 March 2016

Safety Function:

The Ball Valve will move to the designed safe position per the actuator design within the specified safety time.

Application Restrictions:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.



ANSI Accredited Program
PRODUCT CERTIFICATION
#1004



Peter L.

Evaluating Assessor

Steve J. Chase

Certifying Assessor

Systematic Capability: SC 3 (SIL 3 Capable)

Random Capability: Type A, Route 2_H Device

PFD_{AVG} and Architecture Constraints must be verified for each application

Systematic Capability :

The product has met manufacturer design process requirements of Safety Integrity Level (SIL) 3. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.

A Safety Instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.

Random Capability:

The SIL limit imposed by the Architectural Constraints must be met for each element. This device meets *exida* criteria for Route 2_H.

IEC 61508 Failure Rates in FIT*, Ball Valve series BBF

| Variant | without PVST | | | | with PVST | | | |
|---------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|
| | λ_{SD} | λ_{SU} | λ_{DD} | λ_{DU} | λ_{SD} | λ_{SU} | λ_{DD} | λ_{DU} |
| V1 | 0 | 0 | 0 | 488 | 0 | 0 | 172 | 316 |
| V2 | 0 | 0 | 0 | 1263 | 0 | 0 | 172 | 1091 |
| V3 | 0 | 237 | 0 | 364 | 235 | 2 | 172 | 192 |
| V4 | 0 | 0 | 0 | 947 | 0 | 0 | 283 | 664 |
| V5 | 0 | 0 | 0 | 2178 | 0 | 0 | 283 | 1895 |
| V6 | 0 | 459 | 0 | 601 | 454 | 5 | 283 | 318 |

- V1 Close on Trip, Full Stroke, Clean Service
- V2 Close on Trip, Tight Shutoff, Clean Service
- V3 Open on Trip, Clean Service
- V4 Close on Trip, Full Stroke, Severe Service
- V5 Close on Trip, Tight Shutoff, Severe Service
- V6 Open on Trip, Severe Service

* FIT = 1 failure / 10⁹ hours

† PVST = Partial Valve Stroke Test of a final element Device

SIL Verification:

The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFD_{avg} considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each element must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.

The following documents are a mandatory part of certification:

Assessment Report: Boehmer14/07-085-C R001 V1 R0

Safety Manual: Boehmer Safety Manual V1 R0

