

# CERTIFICATE OF CONFORMITY



1. **HAZARDOUS LOCATION ELECTRICAL EQUIPMENT PER CANADIAN REQUIREMENTS**

2. **Certificate No:** FM19CA0048

3. **Equipment:**  
(Type Reference and Name)

*Listing - 1*  
H250/M40 a25bcdefghijklmnopqrstuvwxyz, Flowmeter  
*Listing - 2*  
H250/M40 aG20bcdefghijklmnopqrstuvwxyz, Flowmeter  
*Listing - 3*  
H250/M40 a25bcdefghijklmnopqrstuvwxyz, Flowmeter  
*Listing - 4*  
H250/M40 aG20bcdefghijklmnopqrstuvwxyz, Flowmeter  
*Listing - 5*  
H250/M40 a25bcdefghijklmnopqrstuvwxyz, Flowmeter  
*Listing - 6*  
H250/M40 aG20bcdefghijklmnopqrstuvwxyz, Flowmeter  
*Listing - 7*  
H250/M40 a25bcdefghijklmnopqrstuvwxyz, Flowmeter  
*Listing - 8*  
H250/M40 aG20bcdefghijklmnopqrstuvwxyz, Flowmeter  
*Listing - 9*  
H250/M40 a25bcdefghijklmnopqrstuvwxyz, Flowmeter  
*Listing - 10*  
H250/M40 aG20bcdefghijklmnopqrstuvwxyz, Flowmeter

4. **Name of Listing Company:** Krohne Messtechnik GmbH

5. **Address of Listing Company:**  
Ludwig Krohne Strasse 5  
Duisburg  
D-47058  
Germany

6. The examination and test results are recorded in confidential report number:

3047703 dated 23<sup>rd</sup> September 2013

**Certificate issued by:**

  
J.E. Marquedant  
VP, Manager - Electrical Systems

8 December 2020  
Date

To verify the availability of the Approved product, please refer to [www.approvalguide.com](http://www.approvalguide.com)

**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE**

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA  
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: [information@fmaprovals.com](mailto:information@fmaprovals.com) [www.fmaprovals.com](http://www.fmaprovals.com)

# SCHEDULE



Canadian Certificate Of Conformity No: FM19CA0048

7. FM Approvals LLC, certifies that the equipment described has been found to comply with the following Approval standards and other documents:

CAN/CSA C22.2 No. 0-M91:R2006, CSA-C22.2 No. 0.4:R2013, CSA-C22.2 No. 0.5:R2012, CSA-C22.2 No. 25:R2014, CSA-C22.2 No. 94:R2011, CAN/CSA C22.2 No. 157-92:R2006, CAN/CSA C22.2 No. 213-M1987:R2008, CSA-C22.2 No. 60529:R2005, CAN/CSA-C22.2 No. 60079-0:2011, CAN/CSA-C22.2 No. 60079-11:2006, CAN/CSA-C22.2 No. 60079-15:2006, CAN/CSA-C22.2 No. 61010-1:2009

8. If the sign 'X' is placed after the certificate number, it indicates that the equipment is subject to specific conditions of use specified in the schedule to this certificate.
9. This certificate relates to the design, examination and testing of the products specified herein. The FM Approvals surveillance audit program has further determined that the manufacturing processes and quality control procedures in place are satisfactory to manufacture the product as examined, tested and Approved.
10. Equipment Ratings:

*Listing – 1, Listing – 2*

Intrinsically Safe for Class I, Division 1, Groups A, B, C and D hazardous locations in accordance with drawing APPR\_GD\_821070-01; Intrinsically Safe for Class I, Zone 1, Group IIC hazardous locations in accordance with drawing APPR\_GD\_821070-01, with an ambient temperature rating of -40°C to +65°C.

*Listing – 3, Listing – 4*

Intrinsically Safe for Class I, Division 1, Groups A, B, C and D hazardous locations in accordance with drawing APPR\_GD\_821070-02; Intrinsically Safe for Class I, Zone 1, Group IIC hazardous locations in accordance with drawing APPR\_GD\_821070-02, with an ambient temperature rating of -40°C to +65°C.

*Listing – 5, Listing – 6*

Intrinsically Safe for Class I, Division 1, Groups A, B, C and D hazardous locations in accordance with drawing APPR\_GD\_821070-03; Intrinsically Safe for Class I, Zone 1, Group IIC hazardous locations in accordance with drawing APPR\_GD\_821070-03, with an ambient temperature rating of -40°C to +65°C.

*Listing – 7, Listing – 8*

Intrinsically Safe for Class I, Division 1, Groups A, B, C and D hazardous locations in accordance with drawing APPR\_GD\_821070-04; Intrinsically Safe for Class I, Zone 1, Group IIC hazardous locations in accordance with drawing APPR\_GD\_821070-04, with an ambient temperature rating of -40°C to +65°C.

*Listing – 9, Listing – 10*

Nonincendive for Class I, Division 2, Groups A, B, C, and D hazardous locations; Dust-Ignitionproof for Class II and III, Division 2, Groups E, F and G hazardous locations; Non-sparking for Class I, Zone 2, Group IIC hazardous (classified) locations, indoors and outdoors IP66, IP68, Type 4X and Type 6 with an ambient temperature rating of -40°C to +65°C.

**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE**

FM Approvals LLC, 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: [information@fmaprovals.com](mailto:information@fmaprovals.com) [www.fmaprovals.com](http://www.fmaprovals.com)

# SCHEDULE



Canadian Certificate Of Conformity No: FM19CA0048

11. The marking of the equipment shall include:

*Listing – 1, Listing – 2*

**H250/M40 a25bcdefghijklmnopqrstuvwxyz, Flowmeter**

**H250/M40 aG20bcdefghijklmnopqrstuvwx, Flowmeter**

Class I, Division 1, Groups A, B, C and D; T6

Zone 1[0], Ex ia [ia Ga ] IIC T6 Gb

Control Drawing APPR GD 821070-01

Tamb = -40°C to +65°C;

*Listing – 3, Listing – 4*

**H250/M40 a25bcdefghijklmnopqrstuvwxyz, Flowmeter**

**H250/M40 aG20bcdefghijklmnopqrstuvwx, Flowmeter**

Class I, Division 1, Groups A, B, C and D; T6

Zone 1[0], Ex ia [ia Ga ] IIC T6 Gb

Control Drawing APPR GD 821070-02

Tamb = -40°C to +65°C;

*Listing – 5, Listing – 6*

**H250/M40 a25bcdefghijklmnopqrstuvwxyz, Flowmeter**

**H250/M40 aG20bcdefghijklmnopqrstuvwx, Flowmeter**

Class I, Division 1, Groups A, B, C and D; T6

Zone 1[0], Ex ia [ia Ga ] IIC T6 Gb

Control Drawing APPR GD 821070-03

Tamb = -40°C to +65°C;

*Listing – 7, Listing – 8*

**H250/M40 a25bcdefghijklmnopqrstuvwxyz, Flowmeter**

**H250/M40 aG20bcdefghijklmnopqrstuvwx, Flowmeter**

Class I, Division 1, Groups A, B, C and D; T6

Zone 1[0], Ex ia [ia Ga ] IIC T6 Gb

Control Drawing APPR GD 821070-03

Tamb = -40°C to +65°C;

*Listing – 9, Listing 10*

**H250/M40 a25bcdefghijklmnopqrstuvwxyz, Flowmeter**

**H250/M40 aG20bcdefghijklmnopqrstuvwx, Flowmeter**

Class I, Division 2, Groups A, B, C and D; T6

Class II, III, Division 2, Groups E, F and G; T6

Zone 2, Ex nA IIC T6 Gb

Ta = -40°C to +65°C; Type 4X, Type 6, IP66 and IP68

**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE**

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: [information@fmaprovals.com](mailto:information@fmaprovals.com) [www.fmaprovals.com](http://www.fmaprovals.com)

# SCHEDULE



Canadian Certificate Of Conformity No: FM19CA0048

## 12. Description of Equipment:

**General** - The H250/M40 Flow Meter is designed for direct recording and display of the flow rate of flammable and nonflammable gases and liquids. All signal outputs are available in 4 to 20 mA, HART, and NAMUR communications.

**Construction** - The H250/M40 Flow Meter electronic enclosure is made of aluminum or stainless steel for IS versions and uses the MH040 housing for NI versions. Both the IS and NI versions of the device use the H250 flowtube and guided floats.

**Ratings** - The H250/M40 Flow Meters operate with the following electrical parameters:

### **Indicator M40 ESK4; Terminal 11, 12**

#### **Current Loop:**

$U_i \leq 30V_{dc}$ ;  $I_i \leq 130mA$ ;  $P_i \leq 1W$ ;  $C_i = 0nF$ ;  $L_i \leq 0.01mH$

### **Indicator M40 ESK4-T; Terminal 1, 2 resp. 4, 5**

#### **Binary Output 1 & 2 (NAMUR):**

$U_i \leq 30V_{dc}$ ;  $I_i \leq 130mA$ ;  $P_i \leq 1W$ ;  $C_i \leq 10nF$ ;  $L_i \leq 0.1mH$

### **Indicator M40 ESK4-T; Terminal 1, 3 resp. 4, 6**

#### **Binary Output 1 & 2 (OC):**

$U_i \leq 30V_{dc}$ ;  $I_i \leq 130mA$ ;  $P_i \leq 1W$ ;  $C_i \leq 10nF$ ;  $L_i = 0mH$

### **Indicator M40 ESK4-T; Terminal 7, 8**

#### **Binary Input:**

$U_i \leq 30V_{dc}$ ;  $I_i \leq 130mA$ ;  $P_i \leq 1W$ ;  $C_i \leq 10nF$ ;  $L_i = 0mH$

### **Indicator M40R; Terminal 1, 2 resp. 4, 5**

#### **Limit Switch:**

$U_i \leq 30V_{dc}$ ;  $I_i \leq 100mA$ ;  $P_i \leq 1W$ ;  $C_i = 0nF$ ;  $L_i = 0mH$

### **Indicator M40 K.; Terminal 1, 2 resp. 4, 5**

#### **Limit switch NAMUR:**

SC3,5-NO-Y...

$U_i \leq 16V_{dc}$ ;  $I_i \leq 25mA$ ;  $P_i \leq 34mW$ ;  $C_i \leq 150nF$ ;  $L_i = 150\mu H$

SJ3,5-SN

$U_i \leq 16V_{dc}$ ;  $I_i \leq 25mA$ ;  $P_i \leq 34mW$ ;  $C_i \leq 30nF$ ;  $L_i = 100\mu H$

SJ3,5-S1N

$U_i \leq 16V_{dc}$ ;  $I_i \leq 25mA$ ;  $P_i \leq 34mW$ ;  $C_i \leq 30nF$ ;  $L_i = 100\mu H$

I7S23,5-N

$U_i \leq 16V_{dc}$ ;  $I_i \leq 25mA$ ;  $P_i \leq 34mW$ ;  $C_i \leq 150nF$ ;  $L_i = 150\mu H$

### **Indicator M40 ESK4-FF / ESK4-PA; Terminal D, D- FISCO:**

$U_i \leq 24V_{dc}$ ;  $I_i \leq 380mA$ ;  $P_i \leq 5.32W$ ;  $C_i = 0nF$ ;  $L_i = 0mH$

All other protection techniques, the electronic connection has the following values:

### **Indicator M40 ESK4 with signal output ESK4:**

**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE**

# SCHEDULE



Canadian Certificate Of Conformity No: FM19CA0048

U = 14 - 32V; I = 4...20mA

**Indicator M40 ESK4-T with signal output ESK4 and module I/O:**

U = 14 - 32V; I = 4...20mA

U = 8 - 32V; I = 1...100mA

U = 8V; I ≤ 1 / ≥3mA

U = 8 - 32V; I ≤ 2mA

**Indicator M40 ESK4-FF / ESK4-PA:**

U = 9 - 32V; I = 16mA

**Indicator M40 K:**

U = 8V; I ≤ 1 / ≥3mA

**Indicator M40 R:**

U = 24V; I ≤ 100mA

The H250/M40 Flow Meters are rated for use in an ambient temperature range of -40°C to +65°C. The H250/M40 Flow Meters are rated for use in a process temperature range of -40°C to +300°C.

*Listing - 1*

**H250/M40 a25bcdefghijklmnopqrstuvwxyz, Flowmeter**

Entity Parameters:

Current Loop

U<sub>i</sub> ≤ 30Vdc, I<sub>i</sub> ≤ 130mA, P<sub>i</sub> ≤ 1W, L<sub>i</sub> ≤ 0.01mH, C<sub>i</sub> = 0

Binary Output 1 and/or 2

U<sub>i</sub> ≤ 16Vdc; I<sub>i</sub> ≤ 52mA; P<sub>i</sub> ≤ 169mW

Limit Switch	Type Code Option	C <sub>i</sub> (nF)	L <sub>i</sub> (μH)
SC3,5-NO-Y...	k = 1, 2 or 3	150	150
SJ3,5-SN	k = A, B or C	30	100
SJ3,5-S1N	k = E or F	30	100
I7S23,5-N	k = 5, 6 or 7	150	150

a = Sensor series: V or S

b = Nominal size: 1,2,3,4 or 5

c = Configuration: 4 or 9

d = Process connection: 1,2,3,4,5,6,7,8,A,B,C,D,E,F,G,H,K,L,M,N,P,R,S,T,U,V,W,X, Y or Z

e = Pressure rating: 0,1,2,3,4,7,8,A,B,C,D,G,H,K, L,M,N,P,R,S or V

f = Flange facing: 0,1,3,5,6,7,8,A,C,D,E,F,G,H,L,M,N,P,R,S,U or V

g = Cone: 1,2,3,4,5,6,7,8,A,G,H,K,L,M,N,P or R

h = Float: 1,2,3,4,5,6,A,B,C,D,E,F,G,H,K,L,M,N,P,R,S,T,U,V,W,X,Y or Z

i = Heating jacket: 0,1,2,3,4 or 5

j = Indication: E,F,G,H,K or L

k = Limit switch: 0,1,2,3,5,6,7,A,B,C,E or F

l = Output: 0,8, or C

m = Approval: A

n = Options Indication: 0,2,3,A,B or C

**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE**

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: [information@fmaprovals.com](mailto:information@fmaprovals.com) [www.fmaprovals.com](http://www.fmaprovals.com)

# SCHEDULE



Canadian Certificate Of Conformity No: FM19CA0048

o = Identification: 0,1,2,A,B,C,L,M,N or P  
p = Certificate of compliance: 0 or 1  
q = Confirmation of accuracy: 0,1,2,3,4,5,6 or 7  
r = Pressure- / leakage test: 0,5,6,7,A,B,F,G or H  
s = Material test / -certification: 0,1,2,5,6,F,G,H,L,N or P  
t = Dye penetration test: 0,1 or A  
u = Radiographic examination: 0,1 or A  
v = Hardness test: 0 or 1  
w = Cleaning: 0,1,3,7,A,E,G,K,L,N or P  
x = Design: 0 or B  
y = Flow direction: 0,1,2,3,4 or 5  
z = Manual: 0,1,3 or 4

Listing - 2

**H250/M40 aG20bcdefghijklmnopqrstuvwx, Flowmeter**

Entity Parameters:

Current Loop

$U_i \leq 30V_{dc}$ ,  $I_i \leq 130mA$ ,  $P_i \leq 1W$ ,  $L_i \leq 0.01mH$ ,  $C_i = 0$

Binary Output 1 or 2

$U_i \leq 16V_{dc}$ ;  $I_i \leq 52mA$ ;  $P_i \leq 169mW$

Limit Switch	Type Code Option	$C_i$ (nF)	$L_i$ ( $\mu H$ )
SC3,5-NO-Y...	i = 1, 2 or 3	150	150
SJ3,5-SN	i = A, B or C	30	100
SJ3,5-S1N	i = E or F	30	100
I7S23,5-N	i = 5, 6 or 7	150	150

a = Sensor series: V or S  
b = Configuration: 4 or 9  
c = Material of liner and float: 2,4,A or C  
d = Nominal size / process connection: 1,2,4,5,6,7,A,C,E,F,H or K  
e = Pressure rating: 1,2,B or C  
f = Flange facing: 1 or A  
g = Float: 2,3,4,5,6,7,8,A,B,C,D,E,G,H,K,L,N,P or S  
h = 0  
i = Indication: E,F,G,H,K or L  
j = Limit switch: 0, 1, 2, 3, 5, 6, 7, A, B, C, E or F  
k = Output: 0,8,or C  
l = Approval: A  
m = Options Indication: 0, 2, 3, A, B or C  
n = Identification: 0, 1, 2, A, B, C, L, M, N or P  
o = Certificate of compliance: 0 or 1  
p = Confirmation of accuracy: 0,1,2,3,4,5,6 or 7  
q = Pressure- / leakage test: 0,5, A or F  
r = Material test / -certification: 0,1,2,5, 6, F, G or H  
s = Dye penetration test (PT): 0  
t = Radiographic examination (RT): 0  
u = Hardness test: 0 or 1

**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE**

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: [information@fmapprovals.com](mailto:information@fmapprovals.com) [www.fmapprovals.com](http://www.fmapprovals.com)

# SCHEDULE



Canadian Certificate Of Conformity No: FM19CA0048

v = Cleaning acc. manufacturer standard: 0  
w = Design: 0 or B  
x = Manual: 0,1,3 or 4

*Listing - 3*

**H250/M40 a25bcdefghijklmnopqrstuvwxy, Flowmeter**

Entity Parameters:

Current Loop

$U_i \leq 30V_{dc}$ ,  $I_i \leq 130mA$ ,  $P_i \leq 1W$ ,  $L_i \leq 0.01mH$ ,  $C_i = 0$

Binary Output 1 and/or 2

$U_i \leq 30V_{dc}$ ,  $I_i \leq 100mA$ ,  $P_i \leq 1W$ ,  $L_i = 0$ ,  $C_i = 0$

a = Sensor series: V or S  
b = Nominal size: 1,2,3,4 or 5  
c = Configuration: 4 or 9  
d = Process connection: 1,2,3,4,5,6,7,8,A,B,C,D,E,F,G,H,K,L,M,N,P,R,S,T,U,V,W,X,Y or Z  
e = Pressure rating: 0,1,2,3,4,7,8,A,B,C,D,G,H,K, L,M,N,P,R,S or V  
f = Flange facing: 0,1,3,5,6,7,8,A,C,D,E,F,G,H,L,M,N,P,R,S,U or V  
g = Cone: 1,2,3,4,5,6,7,8,A,G,H,K,L,M,N,P or R  
h = Float: 1,2,3,4,5,6,A,B,C,D,E,F,G,H,K,L,M,N,P,R,S,T,U,V,W,X,Y or Z  
i = Heating jacket: 0,1,2,3,4 or 5  
j = Indication: E,F,G,H,K or L  
k = Limit switch: S,T or U  
l = Output: 0,8,or C  
m = Approval: A  
n = Options Indication: 0,2,3,A,B or C  
o = Identification: 0,1,2,A,B,C,L,M,N or P  
p = Certificate of compliance: 0 or 1  
q = Confirmation of accuracy: 0,1,2,3,4,5,6 or 7  
r = Pressure- / leakage test: 0,5,6,7,A,B,F,G or H  
s = Material test / -certification: 0,1,2,5,6,F,G,H,L,N or P  
t = Dye penetration test: 0,1 or A  
u = Radiographic examination: 0,1 or A  
v = Hardness test: 0 or 1  
w = Cleaning: 0,1,3,7,A,E,G,K,L,N or P  
x = Design: 0 or B  
y = Flow direction: 0,1,2,3,4 or 5  
z = Manual: 0,1,3 or 4

*Listing - 4*

**H250/M40 aG20bcdefghijklmnopqrstuvwx, Flowmeter**

Entity Parameters:

Current Loop

$U_i \leq 30V_{dc}$ ,  $I_i \leq 130mA$ ,  $P_i \leq 1W$ ,  $L_i \leq 0.01mH$ ,  $C_i = 0$

Binary Output 1 and/or 2

$U_i \leq 30V_{dc}$ ,  $I_i \leq 100mA$ ,  $P_i \leq 1W$ ,  $L_i = 0$ ,  $C_i = 0$

**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE**

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: [information@fmaprovals.com](mailto:information@fmaprovals.com) [www.fmaprovals.com](http://www.fmaprovals.com)

# SCHEDULE



Canadian Certificate Of Conformity No: FM19CA0048

a = Sensor series: V or S  
b = Configuration: 4 or 9  
c = Material of liner and float: 2,4,A or C  
d = Nominal size / process connection: 1,2,4,5,6,7,A,C,E,F,H or K  
e = Pressure rating: 1,2,B or C  
f = Flange facing: 1 or A  
g = Float: 2,3,4,5,6,7,8,A,B,C,D,E,G,H,K,L,N,P or S  
h = 0  
i = Indication: E,F,G,H,K or L  
j = Limit switch: S,T or U  
k = Output: 0,8 or C  
l = Approval: A  
m = Options Indication: 0, 2, 3, A, B or C  
n = Identification: 0, 1, 2, A, B, C, L, M, N or P  
o = Certificate of compliance: 0 or 1  
p = Confirmation of accuracy: 0,1,2,3,4,5,6 or 7  
q = Pressure- / leakage test: 0,5, A or F  
r = Material test / -certification: 0,1,2,5, 6, F, G or H  
s = Dye penetration test (PT): 0  
t = Radiographic examination (RT): 0  
u = Hardness test: 0 or 1  
v = Cleaning acc. manufacturer standard: 0  
w = Design: 0 or B  
x = Manual: 0,1,3 or 4

*Listing - 5*

***H250/M40 a25bcdefghijklmnopqrstuvwxyz, Flowmeter***

Entity Parameters:

Current Loop

$U_i \leq 30V_{dc}$ ,  $I_i \leq 130mA$ ,  $P_i \leq 1W$ ,  $L_i \leq 0.01mH$ ,  $C_i = 0$

Binary Output 1 and/or 2

$U_i \leq 30V_{dc}$ ,  $I_i \leq 130mA$ ,  $P_i \leq 1W$ ,  $L_i = 0$ ,  $C_i \leq 10nF$

Binary Input

$U_i \leq 30V_{dc}$ ,  $I_i \leq 130mA$ ,  $P_i \leq 1W$ ,  $L_i = 0$ ,  $C_i \leq 10nF$

a = Sensor series: V or S  
b = Nominal size: 1,2,3,4 or 5  
c = Configuration: 4 or 9  
d = Process connection: 1,2,3,4,5,6,7,8,A,B,C,D,E,F,G,H,K,L,M,N,P,R,S,T,U,V,W,X,Y or Z  
e = Pressure rating: 0,1,2,3,4,7,8,A,B,C,D,G,H,K, L,M,N,P,R,S or V  
f = Flange facing: 0,1,3,5,6,7,8,A,C,D,E,F,G,H,L,M,N,P,R,S,U or V  
g = Cone: 1,2,3,4,5,6,7,8,A,G,H,K,L,M,N,P or R  
h = Float: 1,2,3,4,5,6,7,8,A,B,C,D,E,F,G,H,K,L,M,N,P,R,S,T,U,V,W,X,Y or Z  
i = Heating jacket: 0,1,2,3,4 or 5  
j = Indication: E,F,G,H,K or L  
k = Limit switch: 0

**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE**

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: [information@fmaprovals.com](mailto:information@fmaprovals.com) [www.fmaprovals.com](http://www.fmaprovals.com)

# SCHEDULE



Canadian Certificate Of Conformity No: FM19CA0048

l = Output: 0,8,C or D  
m = Approval: A  
n = Options Indication: 0,2,3,A,B or C  
o = Identification: 0,1,2,A,B,C,L,M,N or P  
p = Certificate of compliance: 0 or 1  
q = Confirmation of accuracy: 0,1,2,3,4,5,6 or 7  
r = Pressure- / leakage test: 0,5,6,7,A,B,F,G or H  
s = Material test / -certification: 0,1,2,5,6,F,G,H,L,N or P  
t = Dye penetration test: 0,1 or A  
u = Radiographic examination: 0,1 or A  
v = Hardness test: 0 or 1  
w = Cleaning: 0,1,3,7,A,E,G,K,L,N or P  
x = Design: 0 or B  
y = Flow direction: 0,1,2,3,4 or 5  
z = Manual: 0,1,3 or 4

*Listing - 6*

***H250/M40 aG20bcdefghijklmnopqrstuvwx, Flowmeter***

Entity Parameters:

Current Loop

$U_i \leq 30\text{Vdc}$ ,  $I_i \leq 130\text{mA}$ ,  $P_i \leq 1\text{W}$ ,  $L_i \leq 0.01\text{mH}$ ,  $C_i = 0$

Binary Output 1 and/or 2

$U_i \leq 30\text{Vdc}$ ,  $I_i \leq 130\text{mA}$ ,  $P_i \leq 1\text{W}$ ,  $L_i = 0$ ,  $C_i \leq 10\text{nF}$

Binary Input

$U_i \leq 30\text{Vdc}$ ,  $I_i \leq 130\text{mA}$ ,  $P_i \leq 1\text{W}$ ,  $L_i = 0$ ,  $C_i \leq 10\text{nF}$

a = Sensor series: V or S  
b = Configuration: 4 or 9  
c = Material of liner and float: 2,4,A or C  
d = Nominal size / process connection: 1,2,4,5,6,7,A,C,E,F,H or K  
e = Pressure rating: 1,2,B or C  
f = Flange facing: 1 or A  
g = Float: 2,3,4,5,6,7,8,A,B,C,D,E,G,H,K,L,N,P or S  
h = 0  
i = Indication: E,F,G,H,K or L  
j = Limit switch: 0  
k = Output: 0,8,C or D  
l = Approvals: A  
m = Options Indication: 0, 2, 3, A, B or C  
n = Identification: 0, 1, 2, A, B, C, L, M, N or P  
o = Certificate of compliance: 0 or 1  
p = Confirmation of accuracy: 0,1,2,3,4,5,6 or 7  
q = Pressure- / leakage test: 0,5, A or F  
r = Material test / -certification: 0,1,2,5, 6, F, G or H  
s = Dye penetration test (PT): 0  
t = Radiographic examination (RT): 0  
u = Hardness test: 0 or 1

**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE**

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: [information@fmaprovals.com](mailto:information@fmaprovals.com) [www.fmaprovals.com](http://www.fmaprovals.com)

# SCHEDULE



Canadian Certificate Of Conformity No: FM19CA0048

v = Cleaning acc. manufacturer standard: 0  
w = Design: 0 or B  
x = Manual: 0,1,3 or 4

*Listing - 7*

**H250/M40 a25bcdefghijklmnopqrstuvwxyz, Flowmeter**

Entity Parameters:

$U_i \leq 24V_{dc}$ ,  $I_i \leq 380mA$ ,  $P_i \leq 5.32W$ ,  $L_i = 0$ ,  $C_i = 0$

a = Sensor series: V or S  
b = Nominal size: 1,2,3,4 or 5  
c = Configuration: 4 or 9  
d = Process connection: 1,2,3,4,5,6,7,8,A,B,C,D,E,F,G,H,K,L,M,N,P,R,S,T,U,V,W,X,Y or Z  
e = Pressure rating: 0,1,2,3,4,7,8,A,B,C,D,G,H,K, L,M,N,P,R,S or V  
f = Flange facing: 0,1,3,5,6,7,8,A,C,D,E,F,G,H,L,M,N,P,R,S,U or V  
g = Cone: 1,2,3,4,5,6,7,8,A,G,H,K,L,M,N,P or R  
h = Float: 1,2,3,4,5,6,7,8,A,B,C,D,E,F,G,H,K,L,M,N,P,R,S,T,U,V,W,X,Y or Z  
i = Heating jacket: 0,1,2,3,4 or 5  
j = Indication: E,F,G,H,K or L  
k = Limit switch: 0  
l = Output: E or F  
m = Approval: A  
n = Options Indication: 0,2,3,A,B or C  
o = Identification: 0,1,2,A,B,C,L,M,N or P  
p = Certificate of compliance: 0 or 1  
q = Confirmation of accuracy: 0,1,2,3,4,5,6 or 7  
r = Pressure- / leakage test: 0,5,6,7,A,B,F,G or H  
s = Material test / -certification: 0,1,2,5,6,F,G,H,L,N or P  
t = Dye penetration test: 0,1 or A  
u = Radiographic examination: 0,1 or A  
v = Hardness test: 0 or 1  
w = Cleaning: 0,1,3,7,A,E,G,K,L,N or P  
x = Design: 0 or B  
y = Flow direction: 0,1,2,3,4 or 5  
z = Manual: 0,1,3 or 4

*Listing - 8*

**H250/M40 aG20bcdefghijklmnopqrstuvw, Flowmeter**

Entity Parameters:

$U_i \leq 24V_{dc}$ ,  $I_i \leq 380mA$ ,  $P_i \leq 5.32W$ ,  $L_i = 0$ ,  $C_i = 0$

a = Sensor series: V or S  
b = Configuration: 4 or 9  
c = Material of liner and float: 2,4,A or C  
d = Nominal size / process connection: 1,2,4,5,6,7,A,C,E,F,H or K  
e = Pressure rating: 1,2,B or C  
f = Flange facing: 1 or A  
g = Float: 2,3,4,5,6,7,8,A,B,C,D,E,G,H,K,L,N,P or S

**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE**

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: [information@fmaprovals.com](mailto:information@fmaprovals.com) [www.fmaprovals.com](http://www.fmaprovals.com)

# SCHEDULE



Canadian Certificate Of Conformity No: FM19CA0048

h = 0  
i = Indication: E,F,G,H,K or L  
j = Limit switch: 0  
k = Output: E or F  
l = Approval: A  
m = Options Indication: 0, 2, 3, A, B or C  
n Identification: 0, 1, 2, A, B, C, L, M, N or P  
o = Certificate of compliance: 0 or 1  
p = Confirmation of accuracy: 0,1,2,3,4,5,6 or 7  
q = Pressure- / leakage test: 0,5, A or F  
r = Material test / -certification: 0,1,2,5, 6, F, G or H  
s = Dye penetration test (PT): 0  
t = Radiographic examination (RT): 0  
u = Hardness test: 0 or 1  
v = Cleaning acc. manufacturer standard: 0  
w = Design: 0 or B  
x = Manual: 0, 1, 3 or 4

## *Listing - 9*

### **H250/M40 a25bcdefghijklmnopqrstuvwxyz, Flowmeter**

a = Sensor series: V or S  
b = Nominal size: 1,2,3,4 or 5  
c = Configuration: 4 or 9  
d = Process connection: 1,2,3,4,5,6,7,8,A,B,C,D,E,F,G,H,K,L,M,N,P,R,S,T,U,V,W,X,Y or Z  
e = Pressure rating: 0,1,2,3,4,7,8,A,B,C,D,G,H,K, L,M,N,P,R,S or V  
f = Flange facing: 0,1,3,5,6,7,8,A,C,D,E,F,G,H,L,M,N,P,R,S,U or V  
g = Cone: 1,2,3,4,5,6,7,8,A,G,H,K,L,M,N,P or R  
h = Float: 1,2,3,4,5,6,7,8,A,B,C,D,E,F,G,H,K,L,M,N,P,R,S,T,U,V,W,X,Y or Z  
i = Heating jacket: 0,1,2,3,4 or 5  
j = Indication: E,F,G,H,K or L  
k = Limit switch: 0,1,2,3,5,6,7,A,B,C,E,F,S,T or U  
l = Output: 0,8,C,D,E or F  
m = Approval: E  
n=Options Indication: 0,2,3,A,B or C  
o = Identification: 0,1,2,A,B,C,L,M,N or P  
p = Certificate of compliance: 0 or 1  
q = Confirmation of accuracy: 0,1,2,3,4,5,6 or 7  
r = Pressure- / leakage test: 0,5,6,7,A,B,F,G or H  
s = Material test / -certification: 0,1,2,5,6,F,G,H,L,N or P  
t = Dye penetration test: 0,1 or A  
u = Radiographic examination: 0,1 or A  
v = Hardness test: 0 or 1  
w = Cleaning: 0,1,3,7,A,E,G,K,L,N or P  
x = Design: 0 or B  
y = Flow direction: 0,1,2,3,4 or 5  
z = Manual: 0,1,3 or 4

## *Listing - 10*

### **H250/M40 aG20bcdefghijklmnopqrstuvw, Flowmeter**

a = Sensor series: V or S

**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE**

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: [information@fmaprovals.com](mailto:information@fmaprovals.com) [www.fmaprovals.com](http://www.fmaprovals.com)

# **SCHEDULE**



Canadian Certificate Of Conformity No: FM19CA0048

b = Configuration: 4 or 9  
c = Material of liner and float: 2,4,A or C  
d = Nominal size / process connection: 1,2,4,5,6,7,A,C,E,F,H or K  
e = Pressure rating: 1,2,B or C  
f = Flange facing: 1 or A  
g = Float: 2,3,4,5,6,7,8,A,B,C,D,E,G,H,K,L,N,P or S  
h = 0  
i = Indication: E,F,G,H,K or L  
j = Limit switch: 0, 1, 2, 3, 5, 6, 7, A, B, C, E, F, S, T or U  
k = Output: 0,8,C,D,E or F  
l = A  
m = Options Indication: 0, 2, 3, A, B or C  
n = Identification: 0, 1, 2, A, B, C, L, M, N or P  
o = Certificate of compliance: 0 or 1  
p = Confirmation of accuracy: 0,1,2,3,4,5,6 or 7  
q = Pressure- / leakage test: 0,5, A or F  
r = Material test / -certification: 0,1,2,5, 6, F, G or H  
s = Dye penetration test (PT): 0  
t = Radiographic examination (RT): 0  
u = Hardness test: 0 or 1  
v = Cleaning acc. manufacturer standard: 0  
w = Design: 0 or B  
x = Manual: 0, 1, 3 or 4

**13. Specific Conditions of Use:**

None

**14. Test and Assessment Procedure and Conditions:**

This Certificate has been issued in accordance with FM Approvals Canadian Certification Scheme.

**15. Schedule Drawings**

A copy of the technical documentation has been kept by FM Approvals.

**16. Certificate History**

Details of the supplements to this certificate are described below:

Date	Description
23 <sup>rd</sup> September 2013	Original Issue.
8 <sup>th</sup> July 2019	<u>Supplement 3:</u> Report Reference: – RR217675 dated 8 <sup>th</sup> July 2019. Description of the Change: Convereted to new certificate format. Update to measurement cone, label and alternative glass manufacture for window cover.

**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE**

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA

T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: [information@fmapprovals.com](mailto:information@fmapprovals.com) [www.fmapprovals.com](http://www.fmapprovals.com)

# SCHEDULE



Canadian Certificate Of Conformity No: FM19CA0048

8 <sup>th</sup> December 2020	<u>Supplement 4:</u> Report Reference: - PR456398 dated 8 <sup>th</sup> December 2020. Description of the Change: Addition of high pressure options for Models K15, K25, K55, K85 and K105 measuring cones bused in the construction of the H250/M40 Variable Area Flowmeter.
-------------------------------	---

**THIS CERTIFICATE MAY ONLY BE REPRODUCED IN ITS ENTIRETY AND WITHOUT CHANGE**

FM Approvals LLC. 1151 Boston-Providence Turnpike, Norwood, MA 02062 USA  
T: +1 (1) 781 762 4300 F: +1 (1) 781 762 9375 E-mail: [information@fmaprovals.com](mailto:information@fmaprovals.com) [www.fmaprovals.com](http://www.fmaprovals.com)