

# Certificate



SIL/PL  
Capability

www.tuv.com  
ID 060000000

**No.: 968/V 1152.00/20**

<b>Product tested</b>	Metallic sealing, triple eccentric butterfly valves	<b>Certificate holder</b>	Zwick Armaturen GmbH Egerstraße 1 58256 Ennepetal Germany
-----------------------	---	---------------------------	--

<b>Type designation</b>	TRI-CON and derivatives acc. to revisionlist
-------------------------	---

<b>Codes and standards</b>	IEC 61508 Parts 1-2 and 4-7:2010
----------------------------	----------------------------------

<b>Intended application</b>	Safety functions: - Closing on Demand and external tightness - Closing on Demand with leakage class A acc. DIN EN 12266-1 and external tightness - Open on demand and external tightness
-----------------------------	---

The valves are suitable for use in a safety instrumented system up to SIL 2. Under consideration of the minimum required hardware fault tolerance HFT=1 the valves may be used in a redundant structure up to SIL 3.

<b>Specific requirements</b>	The instructions of the associated Installation, Operating and Safety Manual shall be considered.
------------------------------	---

Summary of test results see back side of this certificate.

Valid until 2025-05-13

The issue of this certificate is based upon an examination, whose results are documented in Report No. 968/V 1152.00/20 dated 2020-05-13.

This certificate is valid only for products which are identical with the product tested.

**TÜV Rheinland Industrie Service GmbH**  
Bereich Automation  
Funktionale Sicherheit  
Am Grauen Stein, 51105 Köln

Köln, 2020-05-13

Certification Body Safety & Security for Automation & Grid

Dr. R. G. A.

Dr.-Ing. Thorsten Gantevoort

**Holder:** Zwick Armaturen GmbH  
Egerstr. 1  
58256 Ennepetal  
Deutschland

**Product tested: TRI-CON and derivatives**

### Results of Assessment

Route of Assessment		$2_H / 1_S$
Type of Sub-system		Type A
Mode of Operation		Low Demand Mode
Hardware Fault Tolerance	HFT	0
Systematic Capability		<b>SC 3</b>

### Closing on Demand

Dangerous Failure Rate	$\lambda_D$	1.53 E-07 / h	<b>153 FIT</b>
Average Probability of Failure on Demand 1oo1	$PFD_{avg}(T_1)$	6.70 E-04	
Average Probability of Failure on Demand 1oo2	$PFD_{avg}(T_1)$	6.76 E-05	

### Closing in Demand with leakage rate A acc. DIN EN 12266-1

Dangerous Failure Rate	$\lambda_D$	3.02 E-07 / h	<b>302 FIT</b>
Average Probability of Failure on Demand 1oo1	$PFD_{avg}(T_1)$	1.32 E-03	
Average Probability of Failure on Demand 1oo2	$PFD_{avg}(T_1)$	1.34 E-04	

### Open on Demand

Dangerous Failure Rate	$\lambda_D$	1.25 E-07 / h	<b>125 FIT</b>
Average Probability of Failure on Demand 1oo1	$PFD_{avg}(T_1)$	5.48 E-04	
Average Probability of Failure on Demand 1oo2	$PFD_{avg}(T_1)$	5.51 E-05	

Assumptions for the calculations above: DC = 0 %,  $T_1 = 1$  year,  $\beta_{1oo2} = 10$  %

### Origin of failure rates

The stated failure rates for low demand are the result of an FMEDA with tailored failure rates for the design and manufacturing process.

Furthermore the results have been verified by qualification tests and field-feedback data of the last five years. Failure rates include failures that occur at a random point in time and are due to degradation mechanisms such as ageing.

The stated failure rates do not release the end-user from collecting and evaluating application-specific reliability data.

### Periodic Tests and Maintenance

The given values require periodic tests and maintenance as described in the Safety Manual.

The operator is responsible for the consideration of specific external conditions (e.g. ensuring of required quality of media, max. temperature, time of impact), and adequate test cycles.

A time of usage of more than 20 years is acceptable if given cycles are observed.